



HISTORIC  
**FRANKLIN**  
TENNESSEE

September 14, 2016

Ms. Ann Rochelle  
Tennessee Department of Environmental and Conversation  
711 R.S. Boulevard  
Nashville, TN 37243

RE: Overflow Report – 111 Treemont Lane (Treemont 2 Pump Station)  
NPDES Permit # TN0028827

On September 12<sup>th</sup> 2016 at 6:05am we received a call pertaining to an overflow at Treemont 2 pump station located at 111 Tremont Lane. Crews were dispatched to the location and arrived on site at 6:20am. Crews noted the overflow was due to pump failure. Crews turned the backup pump in hand and the overflow ceased at 6:25am. Crews noted the overflow was contained to the ground surface. The estimated volume of the overflow was 100 gallons.

Crews replaced the damaged pump with a new one and the damaged pump was sent back to the pump vendor (Wascon) to rebuild or replace with a new one. Wascon sent a service tech to the location to make repairs to the circuit board. After the repairs were complete, tests were run to make ensure the station was in proper working condition. All corrective actions were complete at 3:45pm.

I have attached the overflow report form and a map of the area for your use. If you have and questions or comments, or if there is any additional information required under our NPDES permit, please do not hesitate to contact us so that we may immediately respond and meet our full obligation under out permit.

Sincerely,

A handwritten signature in black ink, appearing to read 'JR Lee'.

JR Lee  
Assistant Wastewater Collection Superintendent



Treemont Pump Station #2







HISTORIC  
FRANKLIN  
TENNESSEE

## Service Request

### REQUEST INFORMATION

Service Request #: 278293

Request Date: 09/13/2016

Priority: 1

Request Type: SSO Public

Assigned To: 2026

Responsible Dept: WATER MANAGEMENT

Source: PHONE

Caller Comments: WASTEWATER COMING OUT AT TREEMONT 2 PUMP STATION

Additional Comments or Information:

### CONTACT INFORMATION

Name: -

Day Phone #:

Cell Phone #:

Email:

Evening Phone #:

Contact Requested: N

### LOCATION INFORMATION

Service Address: 111 TREEMONT LN

Subdivision: TREEMT

COF Water Service Area:

City Limits: INSIDECOF

Location Details: TREEMONT 2 PUMP STATION

### RESOURCE USAGE

Employee Name / #	Date	Start Time	End Time	Total Hours
4395-2046-1846	9-12-16	6:05 AM	8:30 AM	1 HR 30 MIN

Off Truck #	Out of SR	Part Name	Part Number	Quantity Used

Vehicle	Usage
UNIT 37	1 HR 30 MIN

### Work Comments

ARRIVED ON SITE AT 6:20 AM. TURNED BACKUP PUMP ON. OVERFLOW CEASED AT 6:23 AM. REPLACED DAMAGED PUMP WITH A NEW PUMP. WAGON WAS CALLED TO MAKE REPAIRS AT THE STATION. AFTER REPAIRS WERE COMPLETE, TESTS WERE RUN TO ENSURE THE STATION WAS OPERATING PROPERLY. WAGON LEFT THE

For additional comments, please use back. SITE AT 3:45 PM.

JR Lee

---

**From:** JR Lee  
**Sent:** Monday, September 12, 2016 10:55 AM  
**To:** Ann Rochelle (Ann.Rochelle@tn.gov)  
**Cc:** Michelle Hatcher  
**Subject:** Sanitary Sewer Overflow

Ms. Rochelle,

We had an overflow this morning at Treemont Pump Station #2. The overflow was due to pump failure. Crews noted the overflow was contained to the ground surface. I will send you a report later this week.

Thanks,

JR Lee  
Assistant Wastewater Collection Superintendent  
City of Franklin Public Works  
Water Management Division  
124 Lumber Dr  
Franklin, TN 37064  
(615) 794-4554  
[Jr.lee@franklintn.gov](mailto:Jr.lee@franklintn.gov)

This message has been prepared on resources owned by the City of Franklin, TN. It is subject to the City's Policy for the Use of Computers, Internet and eMail. Messages that are received or created by any City staff member may be a public record subject to Tennessee Open Records Act, T.C.A. 10-7-503, et seq., and the rules of the Open Records Commission. **DO NOT COPY OR FORWARD TO UNAUTHORIZED PERSONS.** This message may contain confidential information and is intended only for the use of the specific individual(s) to which it is addressed. If you are not an intended recipient of this message, you are hereby notified that any unauthorized use, dissemination or copying of this message or any information it contains is strictly prohibited. If you have received this message in error, please delete it and immediately notify the sender by reply email.

**JR Lee**

---

**From:** JR Lee  
**Sent:** Wednesday, September 14, 2016 9:20 AM  
**To:** Ann Rochelle (Ann.Rochelle@tn.gov)  
**Cc:** Juan Davis (juand@franklintn.gov); Melinda White; Michelle Hatcher  
**Subject:** Sanitary Sewer Overflow  
**Attachments:** SKMBT\_C45216091409210.pdf

Ms. Rochelle,

See attached overflow report for 111 Treemont Lane (Treemont #2 Pump Station). If you have any questions or concerns you may reach me via email or the office.

Sincerely,

JR Lee  
Assistant Wastewater Collection Superintendent  
City of Franklin Public Works  
Water Management Division  
124 Lumber Dr  
Franklin, TN 37064  
(615) 794-4554  
[Jr.lee@franklintn.gov](mailto:Jr.lee@franklintn.gov)

This message has been prepared on resources owned by the City of Franklin, TN. It is subject to the City's Policy for the Use of Computers, Internet and eMail. Messages that are received or created by any City staff member may be a public record subject to Tennessee Open Records Act, T.C.A. 10-7-503, et seq., and the rules of the Open Records Commission. **DO NOT COPY OR FORWARD TO UNAUTHORIZED PERSONS.** This message may contain confidential information and is intended only for the use of the specific individual(s) to which it is addressed. If you are not an intended recipient of this message, you are hereby notified that any unauthorized use, dissemination or copying of this message or any information it contains is strictly prohibited. If you have received this message in error, please delete it and immediately notify the sender by reply email.